

Parking Area

Questions	Yes	No	N/A	As Built	Modifications/ Notes
1. Is parking provided at this polling place?				Off-Street On-Street	<u>If NO, Move on to Drop Off Zones Checklist</u>
2. What is the total number of parking spaces in the parking lot designated for voters?					
3. Is there the minimum number of required accessible parking stalls that are designated for a van? (See Table on next page.)					
4. Is there the minimum number of required car accessible parking stalls? (See Table on next page.)					
5. If covered parking is provided, is the entrance to the covered parking a minimum of 98" high?					
6. If covered parking is provided, is the vehicle path from the entrance of the facility to the accessible parking space at least 98 inches high?					
7. If covered parking is provided, does the accessible parking space have a vertical clearance of 98 inches minimum?					
8. If covered parking is provided, Is the exit to the covered parking a minimum of 98" high?					

Table 1
Required Number of Auto and Van Accessible Spaces

THERE MUST ALWAYS BE ONE VAN SPACE

Total Number of Parking Spaces	Required Number of Accessible Spaces	Required Van Accessible spaces	Required Auto Accessible Spaces
1-25	1	1	0
26-50	2	1	1
51-75	3	1	2
76-100	4	1	3
101-150	5	1	4
151-200	6	1	5
201-300	7	2	5
301-400	8	2	6
401-500	9	2	7

The following questions refer to the first required van accessible space.

Questions	Yes	No	N/A	As Built	Modifications/ Notes
<p>9.a. Is there a van accessible space at least 12 feet wide? -AND- Is its access aisle at least 5 feet wide?</p> <p>-OR-</p> <p>9.b. Is there a van accessible space at least 9 feet wide? -AND- Is its access aisle at least 5 feet wide?</p>					
<p>9.c. Is the parking space a minimum of 18 feet long?</p>					
<p>10. Is the access aisle located on the passenger side of the space?</p>					
<p>11.a. Does the top left corner of the van space have a maximum slope of 2.08% in all directions? (See Diagram)</p>					
<p>11.b. Does the top right corner of the van space have a maximum slope of 2.08% in all directions? (See Diagram)</p>					
<p>11.c. Does the bottom right corner of the van space have a maximum slope of 2.08% in all directions? (See Diagram)</p>					
<p>11.d. Does the bottom left corner of the van space have a maximum slope of 2.08% in all directions? (See Diagram)</p>					
<p>11.e. Does the middle of the van space have a maximum slope of 2.08% in all directions? (See Diagram)</p>					
<p>12.a. Does the bottom of the access aisle have a maximum slope of 2.08% in any direction? (See Diagram)</p>					
<p>12.b. Does the middle of the access aisle have a maximum slope of 2.08% in any direction? (See Diagram)</p>					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
12.c. Does the top of the access aisle have a maximum slope of 2.08% in any direction? (See Diagram)					
13. Is the surface of the accessible space and corresponding access aisle stable, firm and slip-resistant?					
14. No ramps are encroaching into the accessible space or access aisle?					
15. Is there an ISA sign next to or in front of the accessible space?					
16. For van accessible spaces, are the words "Van Accessible" added below the ISA on the same or on a separate sign?					
17. Is the bottom edge of the lowest sign at least 60 inches above the ground when the signs are mounted on a pole or wall and it is not in the accessible route to the building entrance?					
18. Is the bottom edge of the lowest sign at least 80 inches above the ground when the signs are mounted in the accessible route?					
19. Is the accessible space located so that a person with a disability would not be compelled to wheel or walk behind parked cars other than their own?					
20. Is the accessible van space on the shortest accessible route to an accessible entrance?					

The following questions refer to the first required auto accessible space.

Questions	Yes	No	N/A	As Built	Modifications/ Notes
21.a. Is there a CAR accessible space at least 9 feet wide?					
21.b. Is the CAR accessible space at least 18 feet long?					
22.a. Is there an auto access aisle 5 feet wide? (Can be shared with another accessible space.)					
22.b. Is the access aisle 18 feet long? (Can be shared with another accessible space.)					
23.a. Does the top left corner of the car space have a maximum slope of 2.08% in all directions? (See Diagram)					
23.b. Does the top right corner of the car space have a maximum slope of 2.08% in all directions? (See Diagram)					
23.c. Does the bottom right corner of the car space have a maximum slope of 2.08% in all directions? (See Diagram)					
23.d. Does the bottom left corner of the car space have a maximum slope of 2.08% in all directions? (See Diagram)					
23.e. Does the middle of the car space have a maximum slope of 2.08% in all directions? (See Diagram)					
24.a. Does the bottom of the access aisle have a maximum slope of 2.08% in all directions? (See Diagram)					
24.b. Does the middle of the access aisle have a maximum slope of 2.08% in all directions? (See Diagram)					
24.c. Does the top of the access aisle have a maximum slope of 2.08% in all directions? (See Diagram)					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
25. Is the surface of the accessible space and corresponding access aisle stable, firm and slip-resistant?					
26. Are ramps encroaching into the accessible space or access aisle?					
27. Is there an ISA sign next to or in front of the accessible space?					
28. Is the bottom edge of the lowest sign at least 60 inches above the ground when the signs are mounted on a pole or wall?					
2J. Is the bottom edge of the lowest sign at least 80 inches above the ground when the signs are mounted in the accessible route?					
H. Is the accessible space located so that a person with a disability would not be compelled to wheel or walk behind parked cars other than their own?					
31. Is the accessible space on the shortest accessible route to an accessible entrance?					

Modifying measures needed at this site on Election Day:

- Need cone/sign to identify accessible space
- Cone off space
- Cone off aisle
- Extend space with tape
- Widen access aisle with tape or cones
- Other

Comments:

Record data for additional accessible spaces here

Photo # and Location:	Yes	No	N/A	Notes
1. Stable, firm, and slip-resistant surface				
2. No ramps in access aisle or accessible space				
3. ISA Sign at accessible space				
4. "Van Accessible" sign under the ISA				
5. The lowest part of the bottom sign is 60 inches minimum above the ground				
6. In the accessible route the bottom of the lowest sign is 80 inches minimum above the ground				
7. Wheeling or walking behind cars other than your own is not required				
8. Accessible space is on the shortest accessible route to an accessible entrance				
9. Covered Parking – vertical clearance 8 feet 2 inches				

