

Accessible Route

When accessible drop-off zones or public transportation points are beyond the polling place property line, the route to the voting area may be extended beyond the property line in an effort to include on street parking and public transportation.

Complete the "Accessible Route" checklist for at least one route provided from each of the following: Parking, Public Transportation, Drop Off Zone, and Public Sidewalk/Property Line.

Describe the location of the accessible route below. For example, "Route from northwest corner crosswalk along sidewalk to bus stop to the walkway to the entrance".


Location of the accessible route:

Questions	Yes	No	N/A	As Built	Modifications/ Notes
1. Is there a route from the specific area of the facility? (i.e. Parking, Property line, Public Transportation)					
2. Is the main route to the voting area free of steps or curbs without ramps?					
3. If no to question 2, is there an alternate route available to the voting area that is free of steps?					
4. If no to question 2, is the alternate route marked with directional signage including an ISA, where the accessible route diverges from the regular route?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
5. Is the route/sidewalk at least 48 inches wide? (or 36 inches at a point due to natural barriers or other existing conditions. A minimum of 32 inches is allowed for a max length of 24 inches.)					
6. Is the surface of the route stable, firm and slip-resistant?					
7. Is the route cross- slope 2.08% or less?					
8. Are any abrupt changes in level from ¼ inch to ½ inch high beveled?					
9. Do changes in level more than ½ inch high have a 5% or lower slope? (If the slope is more than 5%, survey the change in level using the Ramp checklist.)					
10. Are the spaces of any grating, gaps or holes along the route grate than ½ inch?					
11. If there are overhead obstacles lower than 80 inches from the ground along the route, are there cane detectable barriers to prevent someone from walking underneath?					
12. Do all objects mounted on walls from 27 inches to 80 inches high protrude 4 inches or less into the route? (Handrails are permitted to protrude a maximum of 4 ½ inches.)					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
13. Do all objects, mounted on poles from 27 inches to 80 inches high protrude 12 inches or less into the route?					
14. If a curb separates the access aisle from the accessible route to the accessible entrance, is a curb ramp provided? Or can a portable curb ramp be used to create an accessible route from the access aisle to the accessible entrance on election day?					
15. Does an accessible route connect the access aisle to the accessible entrance of the polling place? Or can the route from the access aisle to the accessible entrance be made accessible via modifications on election day?					
16. If modifications are needed at the site, list them out in the Modification/Notes column, or in the Comment box below. Modifications include but are not limited to: temporary ramps, mats to cover grates, directional signage (left and/or right pointing), cones, relocation of items.					

Ramp Figure



Modifying measures needed at this site on Election Day:

- Temporary ramps are needed to cover steps and elevations higher than ½ inch
 _____ Ramps needed
- Need mats to cover grates
 _____ Mats needed
- Directional signage needed for site set-up
 _____ Left pointing signs needed
 _____ Right pointing signs needed
- Cones needed for set-up
 _____ Cones needed
- Items needing temporary relocation:

- Other

Comments: