

## Section 8: Restrooms

**Not all restrooms are open on Election Day. If a restroom is available to the voters, it must be accessible to voters with disabilities.**

☐ **Men's Restroom**

☐ **Women's Restroom**

☐ **Unisex Restroom**

Questions	Yes	No	N/A	Data	Modifications/ Notes
1. Is a Door Checklist completed for this restroom?					
2. If this restroom will be used on Election Day, has a hallway checklist been completed for the accessible route to this restroom?					

### Signs Outside the Restroom

Questions	Yes	No	N/A	Data	Modifications/ Notes
3. Does the restroom have an ISA posted to indicate it is an accessible restroom?					
4. Does the restroom have a wall sign with raised letters and Braille indicating the Men's, Women's or Unisex restroom mounted on the latch side of the door?					
5. Does the wall sign mounted on the latch side of the door have raised characters and Braille with the lowest part of any Braille cell 48 inches or higher above the floor and the bottom of any tactile letter 60 inches maximum above the floor?				Center at 60"	
6. Do the characters on the wall sign contrast with the background?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
7. At the entrance, is there a 12-inch equilateral triangle mounted with the apex pointing upward for the Men's restroom, or a circular sign 12 inch in diameter for the Women's restroom?				Triangle Circle	
8. If a Unisex restroom, at the entrance to the restroom is there a sign showing a 12-inch diameter circle with a 12-inch triangle, in a contrasting color, placed over the circle within the 12-inch diameter mounted with the apex pointing upward?					
9. Is the center of the sign mounted 58 inches to 60 inches above the floor?					
10. Do the sign colors contrast with the wall or door color?					

### Clear Space Inside the Restroom

Questions	Yes	No	N/A	Data	Modifications/ Notes
11. Does the Restroom entrance door encroach into the 60-inch turning space 12 inches or less?					
12. Is there a 30 inch by 48-inch clear space for at least one of each type of fixture?					
13. In a multiple accommodation restroom, is there a clear horizontal floor space 60 inches in diameter with a vertical clearance of at least 27 inches?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
14. In a single accommodation restroom, is there a clear horizontal floor space 60 inches in diameter or a "T" shaped turning space with a vertical clearance of at least 27 inches?					
15. Do all objects mounted on walls from 27 inches to 80 inches high protrude 4 inches or less into the accessible route?					

### Restroom Sink

Questions	Yes	No	N/A	Data	Modifications/ Notes
16. Is there a clear space at least 30 inches by 48 inches at the sink to allow for a forward approach? (Up to 19 inches may extend under the sink.)					
17. Are the sink faucets operable with one hand without tight grasping, pinching, or twisting of the wrist?					
18. Do the faucets require no more than 5 lbs. of force to operate?					
19. If hand-operated metering faucets are used, does the water flow 10 seconds or more when activated?					
20. Is the centerline of the sink at least 18 inches from the adjacent wall or partition panel?					
21. Is the top of the counter or rim of the sink, no higher than 34 inches above the floor?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
22. Underneath the front edge of the counter or sink, is there at least 29 inches of clear space measured from the floor up to the bottom of the counter or sink?					
23. When measuring at a depth 8 inches back from the front edge of the counter or sink, is there at least 27 inches of clear space from the floor up to the bottom of the counter or sink?					
24. Is there toe clear space at least 9 inches high measured at a point 6 inches forward from the back wall?					
25. Are water supply and drainpipes under the sink insulated or arranged to prevent contact?					
26. Is the underside of the sink free from any sharp or abrasive objects?					

### Dispensers

Questions	Yes	No	N/A	Data	Modifications/ Notes
27. Is at least one of each kind of dispenser (i.e. seat cover, soap, paper towel, electric hand dryer, etc.) mounted with the highest operable part and the full range of control motion 40 inches or less above the floor?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
28. Is at least one dispenser of each kind on an accessible route at least 36 inches wide, or 32 inches wide for maximum of 24 inches in length?					
29. Is there a 30 inch by 48-inch clear space for at least one of each kind of dispenser?					
30. Can dispensers be operated with one hand without tight grasping, pinching, or twisting of the wrist?					
31. Is the bottom edge of the reflective portion of the mirror no higher than 40 inches above the floor?					

### The Accessible Stall

Questions	Yes	No	N/A	Data	Modifications/ Notes
32. Is the aisle leading to the accessible stall at least 44 inches wide?					
33. Is there at least 48 inches of perpendicular clear space on the approach side of the stall door?					
34. If the stall door is on the end, is it at least 32 inches wide measured at 90 degrees open?					
35. If the stall door is on the end, is there a clear space at least 60 inches wide and 48 inches long in front of the toilet?					
36. If the stall door is on the side, is it at least 34 inches wide measured at 90 degrees open?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
37. If the stall door is on the side, is there a clear space at least 60 inches wide and 60 inches long in front of the toilet?					
38. Is the accessible stall door self-closing?					
39. Are accessible handles installed on the inside and outside of the stall door near the latch?					
40. Is the accessible stall door equipped with latching hardware that can be operated with one hand without tight grasping, pinching or twisting of the wrist?					

### Toilet, Toilet Paper and Flush Control

Questions	Yes	No	N/A	Data	Modifications/ Notes
41. In a single accommodation restroom is there 28 inches of clear floor space between the side of the toilet and a fixture? (In restrooms constructed prior to 1/1/14, is there at least 32 inches of clear space between one side of the toilet and a wall?)					
42. Is the toilet centerline 17 inches to 18 inches from the closest wall or partition?					
43. Is the top of the toilet seat between 17 inches and 19 inches above the floor?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
44. Is the toilet paper dispenser mounted between 7 inches and 9 inches in front of the toilet? (For toilet paper dispensers installed prior to 1/1/14 is the dispenser mounted no more than 12 inches in front of the toilet?)					
45. Is the toilet paper dispenser at least 19 inches above the floor?					
46. Is the toilet paper dispenser installed below the side grab bar?					
47. Does the toilet paper dispenser allow for continuous feed of toilet paper (i.e. no control of the flow of paper)?					
48. Is the flush control on the clear floor space side of the toilet?					
49. Is the flush control mounted 44 inches or lower?					
50. Does the flush control require 5 lbs. of force or less to operate?					

### Side Grab Bar

Questions	Yes	No	N/A	Data	Modifications/ Notes
51. Is the top of the side grab bar mounted 33 inches to 36 inches above the floor?					
52. Is the side grab bar at least 42 inches long?					
53. Does the side grab bar extend from the rear wall at least 54 inches?					

Questions	Yes	No	N/A	Data	Modifications/ Notes
54. Does the side grab bar extend past the front of the toilet at least 24 inches?					
55. Is the side grab bar mounted with a 1 ½ inch space between the grab bar and the wall?					
56. Is the side grab bar 1 ¼ inches to 2 inches in diameter? See guidelines for non-circular grab bars.					

### Rear Grab Bar

Questions	Yes	No	N/A	Data	Modifications/ Notes
57. Is the top of the rear grab bar mounted 33 inches to 36 inches above the floor?					
58. Is the rear grab bar at least 36 inches long? (24-inch length on centerline ok if adjacent to a recessed fixture.)				24 inches on Center.	
59. Does the rear grab bar extend at least 24 inches from the centerline of the toilet toward the wide side of the toilet stall?				12 inches	
60. Does the rear grab bar extend at least 12 inches from the centerline of the toilet toward the narrow side of the toilet stall?					
61. Is the rear grab bar mounted with a 1 ½ inch space between the grab bar and the wall?					
62. Is the rear grab bar 1 ¼ inches to 2 inches in diameter? See guidelines for non-circular grab bars.					



**Modifying measures needed at this site on Election Day:**

- ☐ Provide directional sign to accessible restroom
  - ☐ Left pointing signs needed
  - ☐ Right pointing signs needed
  - ☐ Signs needed
- ☐ Place temporary Circle or Triangle on restroom door
- ☐ Comments