

Section 8: Restrooms

Not all restrooms are open on Election Day. If a restroom is available to the voters, it must be accessible to voters with disabilities.

Men's Restroom

Women's Restroom

Unisex Restroom

Questions	Yes	No	N/A	Dimension (As Built)	Modifications/ Notes
1. Has a Door Checklist completed for this restroom?					
2. Has an Accessible route and/or Hallway checklist been completed for the route to this restroom? If "No," please complete the appropriate checklist(s).					

Signs Outside the Restroom

Questions	Yes	No	N/A	Dimension (As Built)	Modifications/ Notes
3. Does the restroom have an ISA posted to indicate it is an accessible restroom?					
4. Does the restroom have a wall sign with raised letters and Braille indicating the Men's, Women's or Unisex restroom mounted on the latch side of the door?					
5. Does the wall sign mounted on the latch side of the door have raised characters and Braille with the lowest part of any Braille cell 48 inches or higher above the floor and the bottom of any tactile letter 60 inches maximum above the floor?					
6. Do the characters on the wall sign contrast with the background?					

Questions	Yes	No	N/A	Dimension (As Built)	Modifications/ Notes
7. For men's restrooms, at the entrance, is there a 12- inch equilateral triangle mounted with the apex pointing upward?					
8. For women's restrooms, at the entrance, is there a circular sign 12 inch in diameter for the Women's restroom?					
9. If a Unisex restroom, at the entrance to the restroom, is there a sign showing a 12-inch diameter circle with a triangle, in a contrasting color, placed over the circle with its edges a maximum of ¼ inch from the edge of the circle?					
10. Is the center of the sign mounted 58 inches to 60 inches above the floor?					
11. Do the sign colors contrast with the wall or door color?					

Clear Space Inside the Restroom

Questions	Yes	No	N/A	Dimension (As Built)	Modifications/ Notes
12. (Single Accommodation) Does the restroom door encroach into the 60-inch turning space 12 inches or less?					
13. Is there a 30 inch by 48-inch clear space for at least one of each type of fixture?					
14. (Multiple Accommodation) Is there a clear horizontal floor space 60 inches in diameter or a "T" shaped turning space, both with a vertical clearance of at least 27 inches?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
15. Do all objects mounted on walls from 27 inches to 80 inches high protrude 4 inches or less into the accessible route?					

**Restroom
Lavatory/Sink**

Questions	Yes	No	N/A	As Built	Modifications/ Notes
16. Is there a clear space at least 30 inches by 48 inches at the lavatory/sink to allow for a forward approach? (Up to 19 inches may extend under the					
17. Are the lavatory/sink faucets operable with one hand without tight grasping, pinching, or twisting of the wrist?					
18. Do the faucets require no more than 5 lbs. of force to operate?					
19. If push button or electronic faucets are used, does the water flow for 10 seconds or more when activated?					
20. Is the centerline of the lavatory/sink at least 18 inches from the adjacent wall or partition					
21. Is the top of the counter or rim of the lavatory/sink, no higher than 34 inches above the floor?					

Questions	Yes	No	N/A	Dimension (As Built)	Modifications/ Notes
22. Underneath the front edge of the counter or lavatory/sink, is there at least 29 inches of clear space measured from the floor up to the bottom of the counter or Lavatory/sink?					
23. When measuring at a depth 8 inches back from the front edge of the counter or lavatory/sink, is there at least 27 inches of clear space from the floor up to the bottom of the counter or lavatory/sink?					
24. Is there toe clear space at least 9 inches high measured at a point 6 inches forward from the back wall?					
25. Are water supply and drainpipes under the lavatory/sink insulated or arranged to prevent contact?					
26. Is the underside of the lavatory/sink free from any sharp or abrasive objects?					

Dispensers

Questions	Yes	No	N/A	As Built	Modifications/ Notes
27. Is at least one of each kind of dispenser (i.e. seat cover, soap, paper towel, electric hand dryer, etc.) mounted with the highest operable part and the full range of control motion 40 inches or less above the floor?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
28. Is at least one dispenser of each kind on an accessible route at least 36 inches wide, or 32 inches wide for maximum of 24 inches in length?					
29. Is there a 30 inch by 48-inch clear space for at least one of each kind of dispenser?					
30. Can dispensers be operated with one hand without tight grasping, pinching, or twisting of the wrist?					
31. Is the bottom edge of the reflective portion of the mirror no higher than 40 inches above the floor?					

The Accessible Stall

Questions	Yes	No	N/A	As Built	Modifications/ Notes
32. Is the route leading to the accessible stall at least 44 inches wide?					
33. Is there at least 48 inches of perpendicular clear space on the approach side of the stall door?					
34. (End Door) Is the door opening at least 32 inches wide measured at 90 degrees open?					
35. (End Door) Is there a clear space at least 60 inches wide and 48 inches long in front of the toilet?					
36. (Side Door) Is the door opening at least 34 inches wide measured at 90 degrees open?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
37. (Side Door) Is there a clear space at least 60 inches wide and 60 inches long in front of the toilet?					
38. Is the accessible stall door self-closing?					
39. Are accessible handles installed on the inside and outside of the stall door near the latch?					
40. Is the accessible stall door equipped with latching hardware that can be operated with one hand without tight grasping, pinching or twisting of the wrist?					

Toilet, Toilet Paper and Flush Control

Questions	Yes	No	N/A	As Built	Modifications/ Notes
41. In a single accommodation restroom, does the lavatory/sink encroach into the 60 inch clearance of the toilet? (In restrooms constructed prior to 1/1/14, there can be 28 inches of clear floor space between the side of the toilet and a fixture.)					
42. Is the toilet centerline 17 inches to 18 inches from the closest wall or partition?					
43. Is the top of the toilet seat between 17 inches and 19 inches above the floor?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
44. Is the toilet paper dispenser mounted between 7 inches and 9 inches in front of the toilet? (For toilet paper dispensers installed prior to 1/1/14 is the dispenser mounted no more than 12 inches in front of the toilet?)					
45. Is the toilet paper dispenser at least 19 inches above the floor?					
46. Is the toilet paper dispenser installed below the side grab bar?					
47. Does the toilet paper dispenser allow for continuous feed of toilet paper (i.e. no control of the flow of paper)?					
48. Is the flush control on the clear floor space side of the toilet?					
49. Is the flush control mounted 44 inches or lower?					
50. Does the flush control require 5 lbs. of force or less to operate?					

Side Grab Bar

Questions	Yes	No	N/A	As Built	Modifications/ Notes
51. Is the top of the side grab bar mounted 33 inches to 36 inches above the floor?					
52. Is the side grab bar at least 42 inches long?					
53. Does the side grab bar extend from the rear wall at least 54 inches?					

Questions	Yes	No	N/A	As Built	Modifications/ Notes
54. Does the side grab bar extend past the front of the toilet at least 24 inches?					
55. Is the side grab bar mounted with a 1 ½ inch space between the grab bar and the wall?					
56. Is the side grab bar 1 ¼ inches to 2 inches in diameter? See guidelines for non-circular grab bars.					

Rear Grab Bar

Questions	Yes	No	N/A	Data	Modifications/ Notes
57. Is the top of the rear grab bar mounted 33 inches to 36 inches above the floor?					
58. Is the rear grab bar at least 36 inches long? (24-inch length on centerline ok if adjacent to a recessed fixture.)					
59. Does the rear grab bar extend at least 24 inches from the centerline of the toilet toward the wide side of the toilet stall?					
60. Does the rear grab bar extend at least 12 inches from the centerline of the toilet toward the narrow side of the toilet stall?					
61. Is the rear grab bar mounted with a 1 ½ inch space between the grab bar and the wall?					
62. Is the rear grab bar 1 ¼ inches to 2 inches in diameter? See guidelines for non-circular grab bars.					

Modifying measures needed at this site on Election Day:

Provide directional sign to accessible restroom

_____ Left pointing signs needed

_____ Right pointing signs needed

_____ Signs needed

Place temporary Circle or Triangle on restroom door

Comments